



**OFFICE OF THE DEPUTY FIRE OFFICER  
BALASORE CIRCLE BALASORE**

**FORM-V**

**FIRE SAFETY CERTIFICATE**

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No-54/2020 BLS CLE

Certificate No-59/BLS CLE

Dt-01.12.2020

This certificate is valid up to **30.11.2022**

**(Apply for renewal at least three months before expiry)**

Certified that G+2 Floor Academic International School, over plot No-1550/5060, Khata No-428/479, Mouza-Gaijang, Ps-Bonth, Dist-Bhadrak was inspected by officers of Odisha Fire Service on 07.08.2020 and re-inspected on 29.11.2020 in presence of the Principal, Academic International School, Gaijang, Bonth, Dist-Bhadrak and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019. Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

G Floor-	--- usage---	Class Room, Library, Office, Principal, Director Cabin & Staff common Room
1 <sup>st</sup> Floor -	--- usage---	Class Room, Computer Lab, Art room, & Play Room & Sport Room
2 <sup>nd</sup> floor -	--- usage---	Class Room, Conference hall & sick room

**CONDITIONS:-**

1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier (S) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (S) shall train all staff and occupants periodically to make them well conversant in use and operation of fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all tower/blocks of building/premises.

*(Handwritten Signature)*  
1.12.2020

(Ramesh Chandra Sethy)

Deputy Fire Officer

Balasore Circle, Balasore

**Deputy Fire Officer  
Balasore Circle, Balasore**

Memo No-2280/BLS CLE

date.01.12.2020

Copy submitted to the Principal, Academic International School,  
Ganijang, Bhadrak for information and necessary action.

(Ramesh Chandra Sethy)

Deputy Fire Officer

Balasore Circle, Balasore

**Deputy Fire Officer**

**Balasore Circle, Balasore**

Memo No- /BLS CLE

date. .12.2020

Copy submitted to the Chief Fire Officer, Fire Prevention Wing,  
Directorate, Cuttack for information please.

Sd/-

(Ramesh Chandra Sethy)

Deputy Fire Officer

Balasore Circle, Balasore

Memo No- /BLS CLE

date. .12.2020

Copy forwarded to the Asst. Fire Officer Bhadrak Fire Station for  
information and necessary action.

Sd-

(Ramesh Chandra Sethy)

Deputy Fire Officer

Balasore Circle, Balasore